



# Compliance Statement

## ISO/IEC, EN & TIA Unscreened Class E / Category 6 Four Connector Channel

**EPCT Corporation**  
**1FL., No. 219, Sec. 3, Dadu Road**  
**Beitou District, Taipei City 112, Taiwan, R.O.C.**

### *Compliance Statement No. 113745C*

*This type of Class E / Category 6 unscreened four connector channel has been tested by 3P Third Party Testing and complies with the Class E requirements of Edition 2.2 of ISO/IEC 11801 and CENELEC EN 50173-1:2011, and Category 6 requirements of ANSI/TIA-568-C.2. The Compliance Statement is valid for the channel type in T568B designation and may be suspended or withdrawn if it fails to pass a Maintenance Testing performed not later than 15<sup>th</sup> August 2019. The channel consists of the following EPCT Corporation components:*

<i>Cables:</i>	<i>Horizontal Cable, P/N URO46</i>
	<i>Flexible Cable, From Cords, P/N URT46</i>
	<i>Qualification Status: Manufacturer Verified</i>
<i>Conn. Hardware:</i>	<i>Wall Outlets, P/N EC8224 and P/N EC8225, having PCB marking JE333 D8</i>
	<i>Assembly Box, P/N EC8315, having PCB marking JE342 A1116 E13</i>
	<i>Patch Panels, P/N ECR, having PCB marking IPTB B1110</i>
	<i>P/N ECN, having PCB marking PBT6-KAA V2 C12</i>
	<i>Qualification Status: Manufacturer Verified</i>
<i>Patch Cords:</i>	<i>1,0 m, 2,0 m and 5,0 m: P/N URT46</i>
	<i>Qualification Status: Manufacturer Verified</i>

Hoersholm, 11<sup>th</sup> August 2017

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 11<sup>th</sup> August 2017

*Paul Villien*

Poul Villien  
Coordinating Manager