



# Compliance Statement

## Screened Category 7 ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable

**EPCT Corporation Identification P/N SSO37**  
**Cat. 7, Overall Braid Screened Cable with Foil Screened Twisted Pairs**  
**100  $\Omega$ , 4 Twisted Pairs, 23 AWG, Flame Retardant, PVC, Copper Communication Cable**

**EPCT Corporation**  
**1 FL, No. 219, Sec. 3, Dadu Road, Beitou District,**  
**112 Taipei City, Taiwan, R.O.C.**

**Compliance Statement No. 0473-3P-1220115**

*This Screened ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 7 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6A requirements of Enhanced ANSI/TIA-568.2-D:2018, the requirements of CENELEC EN 50288-4-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to IEC 60332-1-2:2014. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 19 January 2023.*

Hoersholm, 19 January 2022

  
Peter Freiberg Kaas  
Test Responsible

3P Third Party Testing ApS  
Agern Alle 3  
2970 Hørsholm  
Denmark

<https://www.3ptest.dk/>

Hoersholm, 19 January 2022

  
Jens Rytter Petersen  
General Manager