

# Certificate

No. **c9230a-25**

**Customer:**

EPCT Corporation  
1FL., NO.219, SEC.3, Dadu Road, Beitou District  
112 Taipei City, Taiwan (R.O.C.)

**Class I**

**Test sample(s):**

data cable:

**EPCT Corporation Cat.8 Solid Cable, LSZH**

Part no.: ECSR048, 24m

Balanced cord I:

**EPCT Corporation Cat.8 Solid Cable, LSZH equipped with**

**Cat.8 Field Termination Plug**

Part no.: ECSR048 with ECFPX-C8, 3m

Balanced cord II:

**EPCT Corporation Cat.8 S/FTP Stranded, 24AWG, ECFPM patch cord**

Part no.: ECFPM with Cat.8 S/FTP, Stranded, 24AWG, 3m

connecting hardware:

**EPCT Corporation Cat.8 Keystone Jack**

Part no.: KJ58F-C8-FS

**Applied standard(s):**

ISO/IEC 11801-1 Ed.1.0 (2017-11)

DIN EN 50173-1 (2018-10)

**Result(s):**

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.


## 2 Connector Channel, Copper, Class I up to 2GHz

## GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **R9230a-25** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of testing.

Bexbach, 31. January 2025



Dirk Wilhelm, engineer  
(Chairman of the Managing Board)



Test laboratory accredited by DAkkS in accordance with DIN EN ISO/IEC 17025:2018.  
The accreditation is valid for the test methods listed in certificate **D-PL-17559-01-00**.

**GHMT AG**

In der Kolling 320  
66450 Bexbach / Germany

P0 box 11 16  
66442 Bexbach / Germany

T: +49 6826 92 28-0  
F: +49 6826 92 28-290

info@ghmt.de  
www.ghmt.de

**RELIABILITY IN TOTAL  
REQUIRES ACCURACY IN DETAIL.**